

December Interim Superintendents report

1/13/2026

December numbers:

- Average flow = 12.37 MGD
- Rainfall of 2.11 inches
- CBOD of 8 mg/L with 96% removal
- TSS of 4.1 mg/L with 98% removal
- Fecal of 2 MPN
- Final Effluent average turbidity of 1.71 NTU with a low of 0.8 NTU
- 38 trucks to landfill for a total of 638.14 tons of sludge, 19.58 tons grit/screenings
- Volatile Solids Reduction of 58 % on average across the 3 digesters.
- Solar production was 1700 KWH. Down 1105 KWH from last month.
- Micro-turbine production was 82483 KWH. Up 570 KWH from last month.

So far we have met all the requirements for the permit this month. We are still waiting for one result to come in.

We have a mechanic retiring at the end of the month. Marty Hutchings has been here for over 18 yrs. He will be missed.

We have had 2 Operators pass the grade 3 DEC exam. One has taken a grade 3 position, the other has been made an Operator 2 until we have opened another grade 3 slot.

We are starting the DEC and EPA reports that are due at the end of January every year.

I will be working on a year end report to highlight our year's accomplishments, etc..

We continue to make sure all equipment is maintained, update where needed and clean and paint throughout the facility.

Thank you.

Ronald F. Warwick Jr