

January Interim Superintendents report

2/10/2026

January numbers:

- Average flow = 14.62 MGD
- Precipitation of 2.13 inches
- CBOD of 7 mg/L with 96% removal
- TSS of 6 mg/L with 97% removal
- Fecal of 1 MPN
- Final Effluent average turbidity of 1.8NTU with a low of 1.0 NTU
- 37 trucks to landfill for a total of 588.30 tons of sludge, 15.10 tons grit/screenings
- Volatile Solids Reduction of 61% on average across the 3 digesters.
- Solar production was 1626 KWH.
- Micro-turbine production was 77986 KWH.

So far we have met all the requirements for the permit this month. We are still waiting for 4 results to come in.

We have completed and submitted our WTC (wastewater treatment chemical) report for DEC.

We completed and submitted our portion of the CSO Annual report along with City of Binghamton and Village of JC.

We completed and submitted our Annual Flow Certification.

We will be starting our Emerging Contaminant Short Term Monitoring Program in June. This will be at least 4 consecutive quarters of PFAS and Dioxane testing, per DEC.

We are working with GHD on our IWPP annual report and annual solids report.

We continue to make sure all equipment is maintained, update where needed and clean and paint throughout the facility.

Thank you.

Ronald F. Warwick Jr