

October Interim Superintendents report

11/12/2025

October numbers:

- Average flow = 12.24 MGD
- Rainfall of 3.95 inches
- CBOD of 8 mg/L with 96% removal
- TSS of 7 mg/L with 96% removal
- Fecal of 7 MPN
- Final Effluent average turbidity of 2.3 NTU with a low of 1.4 NTU
- 46 trucks to landfill for a total of 750.39 tons of sludge, 21.51 tons grit/screenings
- Volatile Solids Reduction of 63% on average across the 3 digesters.
- Solar production was 5950 KWH. Down 1986 KWH from last month.
- Micro-turbine production was 78,072KWH. 14,926 KWH from last month.

We have met all the requirements for the permit this month.

Unfortunately, our Business Manager, Billie McGovern, has submitted her resignation. Billie has been a valued member of our team, and her contributions and dedication will be sincerely missed. We thank her for her service and wish her the very best in her future endeavors.

Rachel has stepped up and put in an application for the position.

We have started our annual IWPP inspections with GHD. We visited Frito-Lay, Conklin landfill and Buckeye fuel terminal.

We visited CMP Advanced Mechanical Solutions in Binghamton, to determine if they need to be permitted.

We have hired a Mechanics helper.

The team keeps plugging away at operating, maintaining, repairing, and updating systems at the facility.

Thank you,

Ronald F. Warwick Jr

Interim Superintendent