

Superintendents Summary Report for 2025																												
	FLOW	Precip	CBOD5			REM	Tot Susp Solids			REM	Settleable Solids			REM	Total Nitrogen			REM	Phosphorous			REM	Ammonia		CON	TKN		REM
	MGD	Inches	In	out	%	In	out	%	In	out	%	In	out	%	In	out	%	In	out	%	In	out		In	out			
	AVG		Limit				Limit				Limit				Limit				Monitor			Monitor						
			18 mg/L				20 mg/L				0.3 mL/L				6.0 mg/L				1.0 mg/L			1800 lbs./Day			11000 lbs/Day			
Jan	14.56	1.06	200	8	96%	193	4.6	98%	11.90	0.10	99%	23.5	2.8	88%	6.44	0.220	97%	13.5	0.25	98%	23.3	1.3	94%					
Feb	16.21	3.17	171	8	95%	161	3.6	98%	11.60	0.10	99%	21.8	2.9	87%	5.45	0.150	97%	12.8	0.40	97%	21.2	1.5	93%					
Mar	19.99	2.08	132	9	93%	140	7.3	95%	8.60	0.10	99%	18.2	4.3	76%	2.86	0.450	84%	9.0	0.15	98%	17.5	1.8	90%					
Apr	17.38	2.95	168	9	95%	174	5.9	97%	9.90	0.10	99%	22.5	2.8	88%	2.90	0.400	86%	11.8	0.14	99%	22.2	1.6	93%					
May	24.03	5.83	123	9	93%	138	9	93%	15.50	0.10	99%	16.2	2.9	82%	2.36	0.490	79%	7.5	0.20	97%	15.7	1.7	89%					
Jun	16.09	2.58	147	8	95%	171	8	95%	10.90	0.10	99%	18.1	2.6	86%	2.57	0.604	76%	10.3	0.14	99%	18.0	1.7	91%					
Jul	12.67	3.81	180	7	96%	202	7.3	96%	17.70	0.10	99%	23.3	3.4	85%	3.31	0.729	78%	13.4	0.13	99%	23.2	1.7	93%					
Aug	11.29	2.62	200	8	96%	204	6.9	97%	28.90	0.10	100%	25.7	3.9	85%	3.92	0.703	82%	17.4	0.15	99%	25.6	1.7	93%					
Sep	10.85	3.21	210	8	96%	197	8	96%	21.30	0.10	100%	31.6	4.3	86%	4.25	0.758	82%	18.5	0.37	98%	31.5	2.0	94%					
Oct	12.24	3.95	195	8	96%	180	7	96%	20.70	0.10	100%				3.60	0.617	83%	18.4	0.31	98%								
Nov																												
Dec																												
		TOT																										
Avg	15.53	31.26	173	8	95%	176	6.8	96%	15.70	0.10	99%	22.3	3.3	85%	3.77	0.512	85%	13.3	0.22	98%	22.0	1.7	92%					
<p style="text-align: center;"><b>Ammonia limit equates to approx 6 mg/L monthly Avg.(Monitor Only) / TKN limit equates to 38 mg/L Monthly Avg. (Monitor Only)</b></p> <p style="text-align: center;"><b>TN limit is 6.0 mg/L From OO1 (New Limit, Was Monitor) REM = Removal %</b></p> <p style="text-align: center;"><b>The Permit for TN = Rolling 12 Month SUM, from Outfall OO1, (Was O1A) Not to Exceed 639,261 lbs.</b></p> <p style="text-align: center;"><b>Outfall OO1 includes Flow Through O1B (DN Cell Bypass) (Above 35 MGD)</b></p> <p style="text-align: center;"><b>These numbers represent Outfall from OO1</b></p>																												

**Landfill 2025 Summary**

Date	Digested	Lime Stab	Solids Total		Grit and Screen	
	Tons	Tons	Tons	Cost	Tons	Cost
January	680.33	0	680.33	\$27,213.20	19.14	\$861.30
February	653.39	0	653.39	\$26,135.60	21.40	\$963.00
March	736.06	0	736.06	\$29,442.40	21.19	\$953.55
April	693.52	0	693.52	\$27,740.80	29.57	\$1,330.65
May	692.32	0	692.32	\$27,692.80	26.24	\$1,180.80
June	675.12	0	675.12	\$27,004.80	18.79	\$845.55
July	818.70	0	818.70	\$32,748.00	31.75	\$1,428.75
August	783.91	0	783.91	\$31,356.40	27.39	\$1,232.55
September	767.85	0	767.85	\$38,392.50	30.95	\$1,702.25
October	750.39	0	750.39	\$37,519.50	21.51	\$1,183.05
November		0		\$0.00		\$0.00
December		0		\$0.00		\$0.00
Average	725.16		725.16	\$25,437.17	24.79	\$973.45
Sub Total	7,251.59		7,251.59	\$305,246.00	247.93	\$11,681.45

**\$316,927.45**

Annual Cost to Date

\$50 ton for sludge/\$55 ton for grit Starting in September

\$420,000 budgeted for 2025 /

ES8130.54804