

Landfill 2025 Summary						
Date	Digested	Lime Stab	Solids Total		Grit and Screen	
	Tons	Tons	Tons	Cost	Tons	Cost
January	680.33	0	680.33	\$27,213.20	19.14	\$861.30
February	653.39	0	653.39	\$26,135.60	21.40	\$963.00
March	736.06	0	736.06	\$29,442.40	21.19	\$953.55
April	693.52	0	693.52	\$27,740.80	29.57	\$1,330.65
May	692.32	0	692.32	\$27,692.80	26.24	\$1,180.80
June	675.12	0	675.12	\$27,004.80	18.79	\$845.55
July	818.70	0	818.70	\$32,748.00	31.75	\$1,428.75
August	783.91	0	783.91	\$31,356.40	27.39	\$1,232.55
September	767.85	0	767.85	\$38,392.50	30.95	\$1,702.25
October	750.39	0	750.39	\$37,519.50	21.51	\$1,183.05
November	671.26	0	671.26	\$33,563.00	16.74	\$920.70
December		0		\$0.00		\$0.00
Average	720.26		720.26	\$28,234.08	24.06	\$1,050.18
Sub Total	7,922.85		7,922.85	\$338,809.00	264.67	\$12,602.15
\$351,411.15						
Annual Cost to Date						
\$50 ton for sludge/\$55 ton for grit Starting in September						
\$420,000 budgeted for 2025 /						
ES8130.54804						

Superintendents Summary Report for 2025																								
	FLOW	Precip	CBOD5		REM	Tot Susp Solids		REM	Settleable Solids		REM	Total Nitrogen		REM	Phosphorous		REM	Ammonia		CON	TKN		REM	
	MGD	Inches	In	out	%	In	out	%	In	out	%	In	out	%	In	out	%	In	out		In	out		
	AVG		Limit			Limit			Limit			Limit			Limit			Monitor			Monitor			
			18 mg/L			20 mg/L			0.3 mL/L			6.0 mg/L			1.0 mg/L			1800 lbs./Day			11000 lbs/Day			
Jan	14.56	1.06	200	8	96%	193	4.6	98%	11.90	0.10	99%	23.5	2.8	88%	6.44	0.220	97%	13.5	0.25	98%	23.3	1.3	94%	
Feb	16.21	3.17	171	8	95%	161	3.6	98%	11.60	0.10	99%	21.8	2.9	87%	5.45	0.150	97%	12.8	0.40	97%	21.2	1.5	93%	
Mar	19.99	2.08	132	9	93%	140	7.3	95%	8.60	0.10	99%	18.2	4.3	76%	2.86	0.450	84%	9.0	0.15	98%	17.5	1.8	90%	
Apr	17.38	2.95	168	9	95%	174	5.9	97%	9.90	0.10	99%	22.5	2.8	88%	2.90	0.400	86%	11.8	0.14	99%	22.2	1.6	93%	
May	24.03	5.83	123	9	93%	138	9	93%	15.50	0.10	99%	16.2	2.9	82%	2.36	0.490	79%	7.5	0.20	97%	15.7	1.7	89%	
Jun	16.09	2.58	147	8	95%	171	8	95%	10.90	0.10	99%	18.1	2.6	86%	2.57	0.604	76%	10.3	0.14	99%	18.0	1.7	91%	
Jul	12.67	3.81	180	7	96%	202	7.3	96%	17.70	0.10	99%	23.3	3.4	85%	3.31	0.729	78%	13.4	0.13	99%	23.2	1.7	93%	
Aug	11.29	2.62	200	8	96%	204	6.9	97%	28.90	0.10	100%	25.7	3.9	85%	3.92	0.703	82%	17.4	0.15	99%	25.6	1.7	93%	
Sep	10.85	3.21	210	8	96%	197	8	96%	21.30	0.10	100%	31.6	4.3	86%	4.25	0.758	82%	18.5	0.37	98%	31.5	2.0	94%	
Oct	12.24	3.95	195	8	96%	180	7	96%	20.70	0.10	100%	29.1	3.4	88%	3.60	0.617	83%	18.4	0.31	98%	29.0	2.1	93%	
Nov	12.29	1.59				170	5	97%	35.30	0.10	100%				3.64	0.426	88%	15.2	0.48	97%				
Dec																								
		TOT																						
Avg	15.24	32.85	173	8	95%	175	6.6	96%	17.48	0.10	99%	23.0	3.3	85%	3.75	0.504	85%	13.4	0.25	98%	22.7	1.7	92%	
Ammonia limit equates to approx 6 mg/L monthly Avg.(Monitor Only) / TKN limit equates to 38 mg/L Monthly Avg. (Monitor Only)																								
TN limit is 6.0 mg/L From OO1 (New Limit, Was Monitor) REM = Removal %																								
The Permit for TN = Rolling 12 Month SUM, from Outfall OO1, (Was O1A) Not to Exceed 639,261 lbs.																								
Outfall OO1 includes Flow Through O1B (DN Cell Bypass) (Above 35 MGD)																								
These numbers represent Outfall from OO1																								