

Superintendents Summary Report for 2026																							
	FLOW	Precip	CBOD5		REM	TSS		REM	SS		REM	TN		REM	PHOS		REM	Ammonia		CON	TKN		REM
	MGD	Inches	In	out	%	In	out	%	In	out	%	In	out	%	In	out	%	In	out		In	out	
	AVG		Limit			Limit			Limit			Limit			Limit			Monitor			Monitor		
			18 mg/L			20 mg/L			0.3 mL/L			6.0 mg/L			1.0 mg/L			1800 lbs./Day			11000 lbs/Day		
Jan	14.62	2.13	176	7	96%	167	6	96%	32.00	0.10	100%	23.0	3.2	86%	3.30	0.376	89%	1334	18	99%	2711	203	93%
Feb	14.76	1.22	213	11	95%	189	11	94%	19.50	0.10	99%	26.5	4.0	85%	3.73	0.717	81%	1747	89	95%	3023	329	89%
Mar	27.45	5.80	92	7	92%	89	4	96%	5.40	0.10	98%	13.4	4.2	69%	1.40	0.290	79%	1129	15	99%	2762	295	89%
Apr					#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!
May					#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!
Jun					#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!
Jul					#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!
Aug					#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!
Sep					#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!
Oct					#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!
Nov					#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!
Dec					#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!
		TOT																					
Avg	18.94	9.15	160	8	#DIV/0!	148	7.0	#DIV/0!	18.97	0.10	#DIV/0!	21.0	3.8	#DIV/0!	2.81	0.461	#DIV/0!	1403.3	40.67	#DIV/0!	2832.0	275.7	#DIV/0!
<p>Ammonia limit equates to approx 6 mg/L monthly Avg. (Monitor Only) / TKN limit equates to 38 mg/L Monthly Avg. (Monitor Only)</p> <p>TN limit is 6.0 mg/L From OO1 (New Limit, Was Monitor) REM = Removal %</p> <p>The Permit for TN = Rolling 12 Month SUM, from Outfall OO1, (Was O1A) Not to Exceed 639,261 lbs.</p> <p>Outfall OO1 includes Flow Through O1B (DN Cell Bypass) (Above 35 MGD)</p> <p>These numbers represent Outfall from OO1</p>																							

Landfill 2026 Summary							
Date	Digested	Lime Stab	Solids Total	Grit and Screen			
	Tons	Tons	Tons	Cost	Tons	Cost	
January	588.30	0	588.30	\$29,415.00	15.10	\$830.50	
February	521.81	0	521.81	\$26,090.50	18.97	\$1,043.35	
March	622.73	0	622.73	\$31,136.50	31.38	\$1,725.90	
April		0		\$0.00		\$0.00	
May		0		\$0.00		\$0.00	
June		0		\$0.00		\$0.00	
July		0		\$0.00		\$0.00	
August		0		\$0.00		\$0.00	
September		0		\$0.00		\$0.00	
October		0		\$0.00		\$0.00	
November		0		\$0.00		\$0.00	
December		0		\$0.00		\$0.00	
Average	577.61		577.61	\$7,220.17	21.82	\$299.98	
Sub Total	1,732.84		1,732.84	\$86,642.00	65.45	\$3,599.75	
\$90,241.75							
Annual Cost to Date Estimate							
\$50 ton for sludge/\$55 ton for grit							
\$460,000 budgeted for 2026							
ES8130.54804							