

Superintendents Summary Report for 2026																							
	FLOW	Precip	CBOD5		REM	TSS		REM	SS		REM	TN		REM	PHOS		REM	Ammonia		CON	TKN		REM
	MGD	Inches	In	out	%	In	out	%	In	out	%	In	out	%	In	out	%	In	out		In	out	
AVG			Limit			Limit			Limit			Limit			Limit			Monitor			Monitor		
			18 mg/L			20 mg/L			0.3 mL/L			6.0 mg/L			1.0 mg/L			1800 lbs./Day			11000 lbs/Day		
Jan	14.62	2.13	176	7	96%	167	6	96%	32.00	0.10	100%	23.0	3.2	86%	3.30	0.376	89%	1334	18	99%	2711	203	93%
Feb	14.76	1.22	213	11	95%	189	11	94%	19.50	0.10	99%	26.5	4.0	85%	3.73	0.717	81%	1747	89	95%	3023	329	89%
Mar	27.45	5.80	92	7	92%	89	4	96%	5.40	0.10	98%	13.4	4.2	69%	1.40	0.290	79%	1129	15	99%	2762	295	89%
Apr	25.39	3.79	88	5	94%	98	5	95%	5.90	0.10	98%	15.5	4.9	68%	1.76	0.380	78%	1783	10	99%	3054	278	91%
May	17.35	3.17	126	6	95%	108	4	96%	7.30	0.10	99%	20.3	4.4	78%	2.38	0.486	80%	1213	6	100%	2869	206	93%
Jun	13.29	4.28	153	5	97%	135	3	98%	8.90	0.10	99%	23.9	4.1	83%	2.29	0.720	69%	1412	8	99%	2607	188	93%
Jul	11.76	5.46	183	5	97%	236	4	98%	16.40	0.50	97%			#DIV/0!	3.01	0.380	87%	1311	9	99%			#DIV/0!
Aug					#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!
Sep					#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!
Oct					#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!
Nov					#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!
Dec					#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!			#DIV/0!
		TOT																					
Avg	17.80	25.85	147	7	#DIV/0!	146	5.3	#DIV/0!	13.63	0.16	#DIV/0!	20.4	4.1	#DIV/0!	2.55	0.478	#DIV/0!	1418	22	#DIV/0!	2837.7	249.8	#DIV/0!
Ammonia limit equates to approx 6 mg/L monthly Avg. (Monitor Only) / TKN limit equates to 38 mg/L Monthly Avg. (Monitor Only)																							
TN limit is 6.0 mg/L From OO1 (New Limit, Was Monitor) REM = Removal %																							
The Permit for TN = Rolling 12 Month SUM, from Outfall OO1, (Was O1A) Not to Exceed 639,261 lbs.																							
Outfall OO1 includes Flow Through O1B (DN Cell Bypass) (Above 35 MGD)																							
These numbers represent Outfall from OO1																							

	Landfill 2026 Summary							
	Date	Digested	Lime Stab	Solids Total	Grit and Screen			
		Tons	Tons	Tons	Cost	Tons	Cost	
	January	588.30	0	588.30	\$29,415.00	15.10	\$830.50	
	February	521.81	0	521.81	\$26,090.50	18.97	\$1,043.35	
	March	622.73	0	622.73	\$31,136.50	31.38	\$1,725.90	
	April	625.53	0	625.53	\$31,276.50	27.21	\$1,496.55	
	May	691.15	0	691.15	\$34,557.50	21.64	\$1,190.20	
	June	591.93	0	591.93	\$29,596.50	26.92	\$1,480.60	
	July	849.01	0	849.01	\$42,450.50	28.53	\$1,569.15	
	August		0		\$0.00		\$0.00	
	September		0		\$0.00		\$0.00	
	October		0		\$0.00		\$0.00	
	November		0		\$0.00		\$0.00	
	December		0		\$0.00		\$0.00	
	Sub Total	4,490.46		4,490.46	\$224,523.00	169.75	\$9,336.25	
	\$233,859.25							
	Annual Cost to Date Estimate							
	\$50 ton for sludge/\$55 ton for grit							
	\$460,000 budgeted for 2026							
	ES8130.54804							