

June Superintendents report

7/14/2026

June numbers:

- Average flow = 13.29 MGD
- Precipitation of 4.28 inches
- CBOD of 5 mg/L with 97% removal
- TSS of 3.3 mg/L with 98% removal
- Fecal of 5 MPN
- Final Effluent average turbidity of 1.6 NTU with a low of 1 NTU
- 33 trucks to landfill for a total of 591.93 tons of sludge at an average of 2.19% TS and centrifuged to an average of 29% TS, 26.92 tons grit/screenings
- Volatile Solids Reduction of 55 % on average across 3 digesters.
- Solar production was 9,033 KWH.

We have met all the requirements for the permit this month.

We had an anomaly with the TPS power. NYSEG power problem combined with the transfer switch getting stuck in the open position caused no power at TPS for a little over an hour. Matco sent an emergency tech to help reset transfer switch. Generator fired up and transfer switch worked properly. NYSEG found a bad transformer at the pole. Notified the DEC and JC.

We had an employee (Gary Schofield) retire this month with 17 years, 8 months of service.

CMMS had 313 closed PM work orders this month.

We have finished the cleaning and inspections of all CN cells, started DN cells and primary tanks.

We are working on finalizing our portion of the 2027 budget.

We are working on the Emerging Contaminants Survey portion of our permit for the DEC.

This is for PFAS and Dioxane quarterly testing.

Thank you.

Ronald F. Warwick Jr