

August Superintendents report

9/8/2026

August numbers:

- Average flow = 13.72 MGD
- Precipitation of 5.34 inches
- CBOD of 5 mg/L with 97% removal
- TSS of 3.29 mg/L with 98% removal
- Fecal of 10 MPN
- Final Effluent average turbidity of 1.7 NTU with a low of 0.967 NTU
- 49 trucks to landfill for a total of 928.05 tons of sludge at an average of 2.58% TS and centrifuged to an average of 26% TS, 25 tons grit/screenings
- Volatile Solids Reduction of 47 % on average across 3 digesters.
- Solar production was 7,300 KWH.

We have met all the requirements for the permit this month so far. Waiting on 6 days of results.

CMMS closed 544 PM/Correctional work orders this month.

We have completed most cleaning and inspections of equipment.

UV channels will be next as soon as our flow decreases.

Methanol fire suppression system tested and passed.

Fire Extinguishers were inspected and repaired as needed.

Need to get approval for another grade 1 operator to go to Basic Ops class in Morrisville.

Need to get approval for our business manager to go to a conference.

We have a meeting with city and village tonight at 6pm to go over the budget.

Thank you.

Ronald F. Warwick Jr