

September Superintendents report

10/13/2026

September numbers:

- Average flow = 18.21 MGD
- Average influent temperature = 19.86 C/67.75 F
- Precipitation of 5.98 inches
- CBOD of 6 mg/L with 97% removal
- TSS of 3.76 mg/L with 98% removal
- Fecal of 13 MPN
- Final Effluent average turbidity of 2.5 NTU with a low of 1.07 NTU
- 39 trucks to landfill for a total of 754.58 tons of sludge at an average of 2.58% TS and centrifuged to an average of 28% TS, 35.96 tons grit/screenings
- Volatile Solids Reduction of 53.34 % on average across 3 digesters.
- Solar production was 6,204 KWH.

We have met all the requirements for the permit this month so far. Waiting for 1 day of testing results for TKN and TN.

We will be starting our IWPP inspections with GHD.

We are interviewing for an Operator trainee position.

We have an operator with mechanical and electrical ability who would like to move to the shop as a mechanics helper until there is an opening for a mechanic.

We have moved a Grade 2 operator into a Grade 3 operator position after he has passed his DEC test and proven he will make a good Grade 3 operator. He is also interested in becoming a lead shift on second shift after he completes his 6 months as a Grade 3 and proves himself.

Adam recently went to a meeting in Albany with the DEC on training, etc. I will let him elaborate on this.

Electricians are putting lights in one of our Connex's after the mechanics-built shelving in it for spare parts inventory.

CMMS closed 322 PM/Correctional work orders this month.

We continue to maintain and clean the plant for any tours etc.. We have received many compliments on how clean our plant is!!

Thank you.

Ronald F. Warwick Jr